

## Natural Gas Incident Response Summary

**Follow these important guidelines when responding to a natural gas leak, fire, or explosion.**

### **In a Gas Emergency call 1-888-264-8240.**

For more pipeline safety information, please visit our **Natural Gas Safety Certification Program for First Responders:** [firstresponder.domsafety.com/certification](http://firstresponder.domsafety.com/certification)

#### **Do:**

- Keep the local gas utility informed of any developments through your dispatcher.
- Consult with representatives of Dominion Energy or the local pipeline operator, and/or the local gas utility, upon your arrival at the incident scene.
- Evacuate per the DOT Emergency Response Guide.
- Barricade or rope off the area, rerouting pedestrians and traffic if necessary.
- If there is a strong gas odor or your monitoring equipment detects natural gas nearing or exceeding concentrations of 5 percent, evacuate buildings and bystanders.
- Instruct those in the area and building occupants not to turn any electrical equipment on or off. This includes lights, appliances, motors, circuit breakers, and any battery-powered devices.
- Check other buildings in the surrounding area for the presence of gas.
- Call your dispatcher if the situation warrants a discontinuation of electric service to a building.

#### **Don't:**

- Don't enter buildings without wearing personal protective equipment (PPE) and positive pressure SCBA.
- Don't try to extinguish burning gas.
- Don't operate any gas valves, other than the aboveground shutoff valve before the service meter, or appliance supply line shutoff valves.
- Don't open any gas valve that has been shut off.
- Don't park vehicles nearby or leave engines running if a street leak is suspected.
- Don't park in front of buildings where a gas leak is suspected.
- Don't park directly over manhole covers or near storm sewer grates.
- Don't ventilate a building without first coordinating with local gas utility personnel and verifying gas has been shut off and ignition sources have been eliminated.